



BB 10-16-09

MEMORANDUM

To: Dr. J. Brian Sarvis, Superintendent
From: David Hetynok, Director of Facilities and Operations
Subject: Information on sewer line failure at McKinley Elementary School
Date: October 6, 2009

A sewer line has failed at McKinley Elementary school. The affected areas are the Kindergarten building, Healthy Start (southeast end of the cafeteria), cafeteria custodial closet, and the upper grade boys and girls bathrooms (on the southeast end of the main building). A major portion of the failed line is located on a hillside, making repairs difficult and cost prohibitive. A local engineer is investigating alternatives to replacement at the same location. Once we have a design decision, we will proceed with the design and ask the board to declare an emergency to allow the restrooms and other fixtures to be back in service in the least amount of time. Solutions could involve a new sewer connection(s) or a lift station to eliminate as much of the hillside sewer as possible. The bathrooms in the office area, lower grade bathrooms (north end of main building next to playground), and the bathrooms in the portables area are all functional. Portable bathrooms and hand wash stations have been placed on campus and are currently serviced three times a week.

Adams Elementary School	McKinley Elementary School	Roosevelt Elementary School	Goleta Valley Junior High School	Dos Pueblos High School
Cesar Chavez Charter School	Monroe Elementary School	Santa Barbara Charter School	La Colina Junior High School	La Cuesta Continuation High School
Cleveland Elementary School	Open Alternative School	Santa Barbara Community Academy	La Cumbre Junior High School	San Marcos High School
Franklin Elementary School	Peabody Charter School	Washington Elementary School	Santa Barbara Junior High School	Santa Barbara High School
Harding Elementary School				Home School Santa Barbara